

Certificate Number: NSW26209

Certificate of Approval

ISSUED PURSUANT TO THE ELECTRICITY (CONSUMER SAFETY) ACT 2004

ISSUED TO:

Zhejiang Chint Electrics Co., Ltd.

CLASS OF ARTICLE:

Residual Current Device

DESCRIPTION OF ARTICLE:

Residual Current Device

[Two pole or four pole; functionally independent; RCCB Type 'AC', 'A';

Rated Voltage (Un): 240V (1P+N), 415V (3P+N), ac

Rated Current (In): 25A, 40A, 63A;

Rated Residual Operating Current (1P+N): 0.01A (only for In=25A), 0.03A,

0.1A, 0.3A:

Rated Residual Operating Current (3P+N): 0.03A, 0.1A, 0.3A

Rated Residual Making and Breaking Capacity: 630A (63A); 500A (25A,

40A):

Rated Conditional Short Circuit Capacity: 10000A.]

Trade Name or Mark: CHINT

Volts:

Amperes:

Watts:

Hertz:

Other Name Plate Particulars:

EXAMINED FOR COMPLIANCE WITH: AS/NZS 61008.1:2011

TYPE REFERENCE CODE: NL1-63

APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked with Approval Number NSW26209;

or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

DATE OF APPROVAL: 19/03/2013

This approval expires 19/03/2018 unless suspended, cancelled, renewed or extended.

19/3/13

For Commissioner for Fair Trading