



ශ්‍රී ලංකා ප්‍රමිති ආයතනය
இலங்கை கட்டளைகள் நிறுவனம்
SRI LANKA STANDARDS INSTITUTION

අංක 17, වික්ටෝරියා පෙදෙස, ඇල්විටිගල මාවත, කොළඹ 8. කැ.පෙ. } 17 දුරකථනය } 94 11 2671567-72 පැකස් } 94 11 2671579 විදුලි පණිවුඩ: 'ප්‍රමිතා', කොළඹ
 කි. 17, வீக்டோரியா பகுளம், எல்விட்டிகல மாவத்தை, கொழும்பு 8. த. பெ. } தொலைபேசி } 94 11 2672617 பாக்ஸ் } 94 11 2672617 தந்தி: 'பிரமிகா', கொழும்பு
 No. 17, VICTORIA PLACE, ELVITIGALA MAWATHA, COLOMBO 8. SRI LANKA. P. O. Box } TELEPHONE } FAX } Telegrams: 'pramika', Colombo
 E-mail: slsi@slsi.slt.lk Web Site: <http://www.nsf.ac.lk/slsi/>

ඔබේ යොමුව } අපේ යොමුව } II-CMS-RM-143/2 } දිනය } 2005-07-04
 உமது குறிப்பு } எமது குறிப்பு } } திகதி } Date }

Regional Manager – Asia Pacific,
ZHEJIANG CHINT ELECTRICS CO.LTD
CHINT High – tech Industrial Zone,
North Baixian ,Wenzhou, Zhejiang Province
China 325603

Dear Sir,

APPLICATION FOR THE REGISTRATION OF MANUFACTURES UNDER THE IMPORT INSPECTION SCHEME.

I refer to the application submitted to us with respect to the following plant regarding the above registration.

ZHEJIANG CHINT ELECTRICS CO.LTD
CHINT High – tech Industrial Zone,
North Baixian ,Wenzhou, Zhejiang Province
China 325603

I am pleased to inform you that the above plant has been granted the registration for a period of one year by the Sri Lanka Standards institution (SLSI) under the Import Inspection scheme.

For the purpose of import Inspection scheme, SLSI will accept Quality Certificates (QCs) issued by the above plant for the Miniature Circuit Breakers described below, manufactured by the same plant.

A.C air break circuit breakers of types of which the details are given below, for the operation at 50 Hz to 60 Hz having rated voltage not exceeding 440V and

Models : NB1-63, DZ47-60

Types : B , C & D

Ratings : (a) DZ47-60,

$I_{cn} = 3 \text{ kA}$
 $I_n = 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A$

(b) NB1-63,

$I_{cn} = 6 \text{ kA}$
 $I_n = 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A$

Whereas I_{cn} , I_n represent rated short circuit capacity and rated current respectively.

With the grant of the registration every consignment of designated circuit breakers, manufactured by the above plant, exported to Sri Lanka, supported with QCs will be considered for the approval for sale.

However, the QC (a format is annexed hereto) should indicate that the particular consignment has manufactured by the above plant with proper reference to the shipment and the conformance to the Sri Lanka standard, SLS 1175.

Please note that SLSI has the potion to draw samples from the consignments for random check.

Registration will be effective form the date of payment of annual registration fee as indicated in the fee structure annexed hereto in US Dollars or equivalent amount in Sri Lankan rupees including applicable Government taxes.

N.B

It is an offence to use this registration for the promotional works of the product without obtaining a prior approval from the Sri Lanka Standards Institution.

Yours faithfully,



Major. B S De Silva
Director-Quality Assurance
Sri Lanka Standards Institution

Copy to:

Proprietor – INPA Electric Co.,
No.15/6, Col. T G Jayawardena Mawatha,
Colombo 03.