

Certificate

(S) for European Product Safety

Reference No. 405875

Circuit-breakers for overcurrent protection

Type designation

NBH8-40

Certificate holder

Zhejiang Chint Electrics Co. Ltd. Chint High-tech Industrial Zone

North Baixiang Wenzhou, Zhejiang

P.R. CHINA

The product complies with

the standard(s)

EN 60898-1:2003

Date of expiry

19 May 2009

EU Directive information

The product satisfies the provisions for CE marking according to the Low

Voltage Directive 73/23/EEC and 93/68/EEC.

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

Alve Nilsson

Date 19 May 2004





Reference No. 405875

Technical data

Type designation

Rated voltage (V)

230

Rated current (A)

1 -- 40

NBH8-40

rated current (A)

50/60

Frequency (Hz) IP-Class

20

Pattern No.

1+N

Product information

I_{cs} = 4500A. B- and C-Type.

Manufacturing site(s)

Zhejiang Chint Electrics Co. Ltd.

Chint High-tech Industrial Zone

North Baixiang Wenzhou, Zhejiang

P.R. CHINA

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body

Interlek Semko AB, Product Certification

Place Kista - Stockholm

Signed


Alve Nilsson

Date

19 May 2004



Certificate



Reference No. 607783

Circuit-breakers for overcurrent protection

Type designation

NBH8-40H

Certificate holder

Zhejiang Chint Electrics Co., Ltd. Chint High-tech Industrial Zone

North Baixiang 325603 Wenzhou, Zhejiang

CHINA

The product complies with the standard(s) EN 60898-1:2003+A1+A11

Date of expiry

14 August 2011

EU Directive information

The product satisfies the provisions for CE marking according to the Low

Voltage Directive 73/23/EEC and 93/68/EEC.

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body

Intertek Semko AB, Product Certification

Place Kista

Kista - Stockholm

Signed

Alve Nilsson

Date

8 August 2006





Reference No. 607783

Technical data

Type designation/

NBH8-40H

Brand name:

CHNT

Rated Voltage (V) /

240

Rated Current (A) /

1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40

Frequency (Hz) /

50/60

IP-class /

20

Poles No. /

1P+N

Product information /

Ics = Icn = 6000A, B- and C-Type

Manufacturing site(s)

Zhejiang Chint Electrics Co., Ltd. Chint High-tech Industrial Zone North Baixiang 325603 Wenzhou, Zhejiang CHINA

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

Alve Nilsson

Date 8 August 2006