

Certificate



Intertek


for European Product Safety

Reference No. 1124125

Circuit-breaker for overcurrent protection

Type designation	UB
Certificate holder	Zhejiang Chint Electrics Co., Ltd. No.1,Chint Road, Chint Industrial Zone, North Baixiang Yueqing, Zhejiang Province P. R. CHINA
The product complies with the standard(s)	EN 60898-1:2003 and A1+A11+A12
Date of expiry	25 November 2016
EU Directive information	<i>The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.</i>

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Bo Berglöf	Date	25 November 2011 Page 1 of 3

This certificate is issued in accordance with the terms and conditions set out in the Appendix.



Intertek
Appendix

Reference No. 1124125

Technical data

Type designation	UB
Brand name	CHNT
Rated Voltage (V)	240/415
Rated Current (A)	1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A;
Frequency (Hz)	50/60
IP-class	20
Poles No.	1
Product information	B-, C- and D-Type; $I_{cs} = I_{cn}$: 6000A (I_n : 1~40A; B-, C-Type); $I_{cs} = I_{cn}$: 4500A (I_n : 50~63A; B-, C-Type; I_n : 1~63A; D-Type);

Type designation	UB
Brand name	CHNT
Rated Voltage (V)	415
Rated Current (A)	1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A;
Frequency (Hz)	50/60
IP-class	20
Poles No.	2
Product information	B-, C- and D-Type; $I_{cs} = I_{cn}$: 6000A (I_n : 1~40A; B-, C-Type); $I_{cs} = I_{cn}$: 4500A (I_n : 50~63A; B-, C-Type; I_n : 1~63A; D-Type);

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek Appendix

Reference No. 1124125

Type designation	UB
Brand name	CHNT
Rated Voltage (V)	415
Rated Current (A)	1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A (for B-, C-Type); 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A (for D-Type);
Frequency (Hz)	50/60
IP-class	20
Poles No.	3
Product information	B-, C- and D-Type. $I_{cs} = I_{cn}$: 6000A (I_n : 1~40A; B-, C-Type); $I_{cs} = I_{cn}$: 4500A (I_n : 50~63A; B-, C-Type; I_n : 1~63A; D-Type);
Type designation	UB
Brand name	CHNT
Rated Voltage (V)	415
Rated Current (A)	1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A (for B-, C-Type); 6, 10, 16, 20, 25, 32, 40, 50, 60, 63A (for D-Type);
Frequency (Hz)	50/60
IP-class	20
Poles No.	4
Product information	B-, C- and D-Type, $I_{cs} = I_{cn}$: 6000A (I_n : 1~40A; B-, C-Type); $I_{cs} = I_{cn}$: 4500A (I_n : 50~63A; B-, C-Type; I_n : 1~63A; D-Type);
Manufacturing site(s)	Zhejiang Chint Electrics Co., Ltd. No.1,Chint Road, Chint Industrial Zone, North Baixiang, Yueqing Zhejiang Province, P.R. China

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed  Date 25 November 2011
Bo Berglöf

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Ref. Certif. No.

SE-67338

Additional information (if necessary)
Information complémentaire (si nécessaire)

Ue: 240/415V~(1P), 415V~(2P, 3P, 4P);
In: 1-63A; B-, C-Type;
In: 1-63A (for 1-&2-Poles); D-Type;
In: 6-63A (for 3-&4-Poles); D-Type;
Ics= Icn: 6000A (for In: 1~40A; B-, C-Type);
Ics= Icn: 4500A (for In: 50~63A; B-, C-Type; In: 1~63A; D-Type)

Date: 25 November 2011

Signature: 