

# GINDRE DUCHAVANY

<b>INSPECTION CERTIFICATE 3.1</b> <b>EN 10204</b>	Date: 13/11/2019 Nr : RCF232980-0		
MGI S.A. AV. GRAL. FLORES 2199 . MONTEVIDEO-URUGUAY URUGUAY	Our Order Nr :  GD084277*3 - F628135	Order Qty :  20 P	
	Your Order Nr:  PEDIDO DEL 23/10/2019		
CUETP HRF77-91 BARRA DE COBRE 80X10MM CANTADO MATADO (1MM) IN 4000MM-0/+100 ASTMB152 CAJAS MARITIMAS			
ASTM B152  Drawing Nr :  Your Item Ref :     BC80X10	CUA1 HRF77-91 80X10 R1 BA  CW004A/CuA1/E-Cu57/C101/_/C11000		
<b>Parameters</b>	<b>Min</b>	<b>Max</b>	<b>Values</b>
WIDTH	79.8	80.2	80.02     mm
THICKNESS	9.92	10.08	10.06     mm
CONDUCTIVITY	97.16		100.5     %IACS
HARDNESS HRF	77	91	80
TENSILE STRENGTH	245	350	259     N/mm <sup>2</sup>
ELONGATION	15		30.63     %
COPPER CONTENT	99.9		99.99     %
SILVER CONTENT	99.9		%     %
<b>WEIGHT CONTROLLED (KG)</b>			<b>583.00</b>
This certificate is generated automatically and valid without personal sign We hereby certify that the material described above complies with terms of the order contract			
Certificat ISO 9001  INTERTEK 0044840-00	Page: 1/1		Quality ASSURANCE D.  PEDRO Jean Paul