

GINDRE DUCHAVANY

INSPECTION CERTIFICATE 3.1 EN 10204	Date: 12/11/2019 Nr : RCF232931-0		
MGI S.A. AV. GRAL. FLORES 2199 . MONTEVIDEO-URUGUAY URUGUAY	Our Order Nr : GD084277*4 - F628134	Order Qty : 20 P	
	Your Order Nr: PEDIDO DEL 23/10/2019		
CUETP HRF77-91 BARRA DE COBRE 80X5MM CANTADO MATADO (1MM) IN 4000MM-0/+100 ASTMB152 CAJAS MARITIMAS			
ASTM B152 Drawing Nr : Your Item Ref : BC80X5	CUA1 HRF77-91 80X5 R1 BA CW004A/CuA1/E-Cu57/C101/_/C11000		
Parameters	Min	Max	Values
WIDTH	79.8	80.2	80.01 mm
THICKNESS	4.92	5.08	4.99 mm
CONDUCTIVITY	57		58.7 MS/m
HARDNESS HRF	77	91	83
RESISTIVITY		0.15775	0.01703 Ohm.g/m2
TENSILE STRENGTH	245	350	272 N/mm ²
ELONGATION	15		25.44 %
COPPER CONTENT	99.9		99.97 %
WEIGHT CONTROLLED (KG)			291.00
This certificate is generated automatically and valid without personal sign We hereby certify that the material described above complies with terms of the order contract			
Certificat ISO 9001 INTERTEK 0044840-00	Page: 1/1		Quality ASSURANCE D. GENILLON Rémy