

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 030702 - E205607

ISSUE DATE: July 3, 2002



Issued to: Chint Group Corp.
Chint Industrial Zone
Wenzhou, Zhejiang 325604 CHINA

Report Reference: E205607, June 19, 2002



This is to Certify that representative samples of: Definite Purpose Magnetic Contactors, Models NR2, followed by any number, followed by 25, 36 or 93, followed by Z or E

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 508, Standard for Industrial Control Equipment
CAN/CSA C22.2 No. 14, Industrial Control Equipment


Additional Information: See Addendum

Only those products bearing the UL Recognized Component Markings for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Marking for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Markings. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Marking for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory

LOOK FOR THE UL RECOGNIZED COMPONENT MARKING ON THE PRODUCT

Engineer: 
Iris Schoeffler/Project Handler I
Underwriters Laboratories Inc.

Review Engineer: 
R. E. Lichtner/Engineering Group Leader
Underwriters Laboratories Inc.



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 030702 - E205607
ISSUE DATE: July 3, 2002



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS :

Model	Rated A	Setting Range, A	AWG	Matched contactors
NR2-25	0.16	0.1 - 0.16	18	CJX2-09
	2	1.25 - 2	18	CJX2-09
	13	9 - 13	14	CJX2-12
	18	12 - 18	2	CJX2-18
	25	17 - 25	10	CJX2-25
NR2-36	32	23 - 32	8	CJX2-32
	36	28 - 36	8	CJX2-36
NR2-93	65	48 - 65	4	CJX2-50
	32	23 - 32	8	CJX2-40
	93	80 - 93	2	CJX2-95

Rated trip A - 120% of rated current
 Rated load A - 100% of rated current
 Rated load A of auxiliary circuit - 5 A
 AWG of auxiliary circuit - 20
 Rated V - 600
 Short circuit - 600 V, 5000 rms symmetrical amperes

Engineer: *Iris Schoeffler*
 Iris Schoeffler/Project Handler I

Review Engineer: *R. E. Lichtner*
 R. E. Lichtner/Engineering Group Leader